

Asbestos Registry

Type of Facility (e.g., healthcare, school, government building, crown building): Healthcare

Name of RHA, School District or Crown (if applicable): Kelsey Trail Health Region

Owner Name (if applicable): Kelsey Trail Health Region

Location (Street address, City): Broadway Avenue Melfort

Facility Name (if applicable): Broadway School

Date of Submission: November 28, 2014

Contact Person: Trent Mitchell Title: Director of Information Management & Building Services

Telephone: 306-752-7594 Email: tmitch@kthr.sk.ca

1. Type of Asbestos-Containing Material [ACM] (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (optional)
Floor tile 9X9	Gym-Auditorium under stage area, also west fan room	5% Chrysotile, 95% Non-Fibrous	Low - can be locked, so no access.	Condition- Some Damage, Do not require removal unless renovating or demolition.
Fire Doors	Boiler Room		Low - can be locked, so no access.	Condition- Excellent no remediation required. Do not require removal unless renovating or demolition.

