

Asbestos Registry

Type of Facility (e.g., healthcare, school, government building, crown building): Healthcare

Name of RHA, School District or Crown (if applicable): Kelsey Trail Health Region

Owner Name (if applicable): Kelsey Trail Health Region

Location (Street address, City): 4101 – 1st Avenue West Carrot River

Facility Name (if applicable): Carrot River Health Centre

Date of Submission: November 28, 2014

Contact Person: Trent Mitchell Title: Director of Information Management & Building Services

Telephone: 306-752-7594 Email: tmitch@kthr.sk.ca

1. Type of Asbestos-Containing Material [ACM] (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (optional)
Elbow, Cold Water Return	Boiler Room East Crawl Space	60-65% Chrysotile, 35% Non-Fibrous 4-pieces-friable, 1 piece-Poor, 2-pieces-good	Medium - this is in the basement of the facility; in an area only accessible to the staff. Staff can be working in this area. Note: some of this has been removed in Dec 2014; more are to be removed in summer of 2015.	4-pipe fittings – further inspection pending
Vermiculite in Walls	Main Floor Fire Walls	3-5% Asbestos, 95% Non-Fibrous	Low - due to the building materials and covered with paint. Access to all persons in the building.	Condition-good
Vermiculite in Attics	Main Floor Ceiling	3-5% Asbestos, 95% Non-Fibrous	Low - This is in an area only accessible to the staff.	Condition-Poor Loose fill in Attic – restrict access

