

Asbestos Registry

Type of Facility (e.g., healthcare, school, government building, crown building): Healthcare

Name of RHA, School District or Crown (if applicable): Kelsey Trail Health Region

Owner Name (if applicable): Kelsey Trail Health Region

Location (Street address, City): 401 Burns Avenue East Melfort

Facility Name (if applicable): Nirvana Lodge

Date of Submission: November 28, 2014

Contact Person: Trent Mitchell Title: Director of Information Management & Building Services

Telephone: 306-752-7594 Email: tmitch@kthr.sk.ca

1. Type of Asbestos-Containing Material [ACM] (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (optional)
Stipple Ceiling	Room 154 Main Floor	1-2% Chrysotile, 98% Non-Fibrous	Medium - sealed up high, can be accessed.	Condition-Good
Stipple Ceiling	Room 133 Main Floor	2-3% Chrysotile, 97% Non-Fibrous	Medium - sealed up high, can be accessed.	This is for all ceilings at Nirvana.
Stipple Ceiling	Sunset Area Main Floor	4-5% Chrysotile, 95% Non-Fibrous	Medium - sealed up high, can be accessed.	
Stipple Ceiling	Medical Clinic Reception Area	2-5% Chrysotile, 95% Non-Fibrous	Medium - sealed up high, can be accessed.	
Stipple Ceiling	Medical Clinic Kid's Play Area	2-5% Chrysotile, 95% Non-Fibrous	Medium - sealed up high, can be accessed.	

