

Asbestos Registry

Type of Facility (e.g., healthcare, school, government building, crown building): Healthcare

Name of RHA, School District or Crown (if applicable): Kelsey Trail Health Region

Owner Name (if applicable): Kelsey Trail Health Region

Location (Street address, City): 330 Oak Street Porcupine Plain

Facility Name (if applicable): Red Deer Nursing Home

Date of Submission: November 28, 2014

Contact Person: Trent Mitchell Title: Director of Information Management & Building Services

Telephone: 306-752-7594 Email: tmitch@kthr.sk.ca

1. Type of Asbestos-Containing Material [ACM] (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (optional)
Elbow on Air Handling Unit	Boiler Room North Side	75-80% Chrysotile, 10% Non-Fibrous, 5% Cellulose, 5% Glass Fibers	Medium - staff can be working in this area.	Pipe fittings-6 small, 2 medium-condition- poor – further investigation pending
Elbow on Steam Line	Locker Room West Side-	60-70% Chrysotile, 10% Non-Fibrous, 10% Cellulose, 10% Glass Fiber	Medium - staff can be working in this area.	Pipe fittings-2 Medium, 4 large- Condition poor – further inspection pending.
Elbow on Steam Line	Laundry Room East Side-	75-80% Chrysotile, 10% Non-Fibrous, 5% Cellulose, 5% Glass Fiber	Medium - staff can be working in this area.	Pipe fittings-1 small, 1 medium-condition- fair minor damage.
				Pipe fittings-78 small, 22 medium, 7 large- Condition- Excellent

