

Asbestos Registry

Type of Facility (e.g., healthcare, school, government building, crown building): Healthcare

Name of RHA, School District or Crown (if applicable): Kelsey Trail Health Region

Owner Name (if applicable): Kelsey Trail Health Region

Location (Street address, City): 901-108th Avenue Tisdale

Facility Name (if applicable): Regional Office

Date of Submission: November 28, 2014

Contact Person: Trent Mitchell Title: Director of Information Management & Building Services

Telephone: 306-752-7594 Email: tmitch@kthr.sk.ca

1. Type of Asbestos-Containing Material [ACM] (or groups of ACM)	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments (optional)
Floor Tiles 9X9	Storage Room North Wall	1-3% Chrysotile, 97% Non-Fibrous	Medium - Easy access.	Condition- Excellent
Elbow-open with no covering			Low - in locked rooms outside.	Pipe fittings-10 small- Condition poor – further inspection pending Pipe fittings-10 Medium- Condition poor – further inspection pending

